

## WATER SUPPLIES

## Acceptable Solution G12/AS1

### 5.5 Maintenance facilities

Amend 13  
Nov 2023

- 5.5.1** The *water supply system* shall be provided with an isolating valve where a supply pipe enters the *building* or at each Dwelling unit within a Multi-unit dwelling.
- 5.5.2** Where the water supply pipe serves a Detached dwelling, the isolating valve required by Paragraph 5.5.1 may be located at the property boundary.

Amend 13  
Nov 2023

#### COMMENT:

Additional isolating valves may be provided for the maintenance of *storage water heaters*, valves and components.

Amend 13  
Nov 2023

- 5.5.3** Provision shall be made for draining *storage water heaters* in accordance with Figure 7.

Amend 13  
Nov 2023